





Integration of Distributed Solar PV Generations into Secondary Distribution Grid



Electricity Market Operation in India





Motivation: ABT





Motivation: UI/Charges of Deviation



- Known as Unscheduled Interchange (UI) Charges till 17th Feb 2014
- Varies inversely with system frequency




Frequency range	Rate in Rs per KWh									
	49.70	49.75	49.80	49.85	49.90	49.95	50.00	50.05	50.10	
<p>No over drawl is allowed.</p> <p>Overdrawl @ 16.48 Rs / KWh i.e. 100% additional charge of Freq 49.70 Hz</p>	8.24	6.99	5.94	4.90	3.86	2.82	1.78	0.00	0.00	<p>Under drawl / over injection Penalty @ 1.78 per KWh</p>

Power Scenario in India

All India Power Installed Capacity (as on 31st July 2014)



Power from Renewable Energy Sources




RE based power generation :
 ~ 20% growth in last 5 years

Wind energy (21,132 MW) continues to dominate - 67 % of total RE



Solar power : 2,647 MW

As on 31st March 2014

Technology-wise Renewable Energy Installed capacity (MW)




Wind and Solar Energy Sources



Cumulative Capacity Addition of Solar Power

NSM Phase - I, Batch - 1, Projects under Gujarat Solar Policy


NSM Phase - I, Batch - 2, Solar REC based Projects




Sr. No.	States	Installed Capacity (MW)
1	Andhra Pradesh	131.84
2	Arunachal Pradesh	0.0025
3	Chhattisgarh	7.1
4	Delhi	5.15
5	Goa & UT	8.66
6	Gujarat	916.4
7	Haryana	10.3
8	Jharkhand	16
9	Karnataka	31
10	Kerela	0.025
11	Madhya Pradesh	347.17
12	Maharashtra	249.25
13	Odisha	30.5
14	Punjab	16.85
15	Rajasthan	730.1
16	Tamil Nadu	98.36
17	Uttarakhand	5.05
18	Uttar Pradesh	21.075
19	West Bengal	7.05
Total		2631.88

Promoting the adoption of RE resources by encouraging private sector investment and mandating the use of RE generation

Ample opportunities for the establishment of land-based RE generation as well as for offshore wind farms



Key drivers of renewable energy in India



India ranks 4th and 6th globally as the largest importer of oil, and of petroleum products and LNG, respectively. The increased use of indigenous renewable resources is expected to reduce India's dependence on expensive imported fossil fuels.


NAPCC – promoting the understanding, adaption and mitigation of climate change, energy efficiency and resource conservation

RE is distributed and scalable resource, making it well suited to meet the need for power in remote areas, which lack grid and road infrastructure


Power Distribution Network of IITGN-VGEC Campus



Supply From Utility
(Torrent Power Ltd.)



100 kW Multi-crystalline
PV plant, 25 kVA x 4
inverters, ABB




10 kW_p Solar PV (**Thin-film, CIS**) System



Pyranometer

Pyranometer and Irradiance sensors with module temperature sensor



Thermocouple

Ambient temperature sensor

Installed by

NTT Facilities, Inc., Japan
Total 64 PV modules (Thin-film, CIS)

PV module

Manufacturer : Solar Frontier, Japan
Type : CIS (SF150-L)
Nominal value : 150 W_p

(<http://www.solar-frontier.com>)

Installation conditions

Inclined angle : 25°
Orientation : South

Installed in January 2012

Naran Pindoriya, IITGN




Inverter & Data logger

PV Inverter (REFU_{sol} 010K)

Data logger (Solar-Log 200)




String junction box with surge protection






10 kW_p Solar PV (**Thin-film, CIS**) System




Solar PV system performance from January to May & June to December in 2012




10 kW_p Solar PV (Thin-film, CIS) System



Solar PV Profile over a day




Date	Time	Pac (W)	Energy (Wh)	Pdc (W)	Vdc (V)	Vac (Vph)	Sollrr (W/m2)	Tmp Mod	Tmp Amb	DaySumlrr (Wh/m2)
24.02.13	13:35:00	9246	39500	9373	628	248	1009	57	29	3998
24.02.13	13:30:00	9323	38700	9449	628	249	1018	57	29	3923
24.02.13	13:25:00	9328	37900	9453	627	249	1022	57	29	3846
24.02.13	13:20:00	9321	37200	9450	627	249	1021	57	29	3770
24.02.13	13:15:00	9402	36400	9531	628	248	1031	55	29	3694
24.02.13	13:10:00	9471	35600	9599	630	249	1035	55	29	3616
24.02.13	13:05:00	9545	34800	9674	630	250	1046	57	28	3538
24.02.13	13:00:00	9432	34000	9558	628	249	1037	58	28	3460
24.02.13	12:55:00	9450	33200	9579	628	248	1043	58	29	3382
24.02.13	12:50:00	9533	32400	9667	632	248	1042	55	28	3305
24.02.13	12:45:00	9537	31700	9674	634	247	1040	54	28	3226
24.02.13	12:40:00	9554	30900	9702	634	247	1042	54	28	3148
24.02.13	12:35:00	9568	30100	9712	636	248	1041	54	28	3069
24.02.13	12:30:00	9485	29300	9627	637	247	1032	54	28	2990
24.02.13	12:25:00	9522	28500	9679	640	247	1034	53	28	2912
24.02.13	12:20:00	9403	27700	9545	637	247	1024	54	27	2834
24.02.13	12:15:00	9481	26900	9621	636	247	1037	55	27	2756
24.02.13	12:10:00	9288	26400	9427	634	246	1018	55	27	2679






10 kW_p Solar PV (Thin-film, CIS) System




Statistical (Average) performance (so far in 2014)

- **Energy: 54 kWh/day**
- **Sun Energy: 5.5 kWh/m²/day**
- **CUF: 22.5**



10 kW_p Solar PV (**Thin-film, CIS**) System



Rain started in June month in 2013 whereas it was started in July in 2012

- It has been observed that *winter season is most favorable* weather condition for solar PV power generation
- Energy generation in *March month is the highest* across the year
- The performance in *rainy season (July-Sept) is so much intermittent* which essentially drops the total power generation in this season



10 kW_p Solar PV (Multicrystalline Silicon) System



Pyranometer and Irradiance sensors with module temperature sensor



PV Inverter (REFUsoI 010K)



Anemometer (Madgetech, 101A)

Installed by

Gujarat Energy Development Agency (GEDA), Gandhinagar
Total 44 PV modules (Multicrystalline Silicon)

PV module

Manufacturer : Jain Photovoltaic
Type : JJ - M660
Nominal value : 230 W_p


(<http://www.jains.com/Solar/jain%20jyot/Models%20-%2010%20to%20230%20watt.htm>)

Installation conditions

Inclined angle : 21°
Orientation : South

Installed in February 2012

Naran Pindoriya, IITGN




P _{max}	230 W _p
V _{mpp}	30.26 V
I _{mpp}	7.55 A
V _{oc}	36.35
I _{sc}	8.15

10 kW_p Solar PV (Multicrystalline Silicon) Rooftop System




Solar PV system performance from May to December in 2012




Operational failure sometimes happened because of unstable distribution grid conditions




10 kW_p Solar PV (**Multicrystalline Silicon**) System



- Energy generation in **March month** is the highest across the year
- The performance **in rainy season (July-Sept) is so much intermittent** which essentially drops the total power generation in this season



The Impact Investigation Exercise



Kalpesh Joshi and N.M. Pindoriya, "Impact Investigation of Rooftop Solar PV System: A Case Study in India," 2012 3rd IEEE PES Innovative Smart Grid Technologies Europe (ISGT Europe), Berlin, October 14-17, 2012, pp. 1-8.

The Impact Investigation Exercise

Case 1

- Base case study
- Balance load, without capacitor compensation and solar PV generation

Case 2

- With capacitor compensation
- Balance load, without solar PV generation

Case 3



- With solar PV generation
- Balance load, without capacitor compensation

Case 4



- With capacitor compensation & solar PV generation
- Balance load

Case 5


- Unbalance load
- With capacitor compensation & solar PV generation



The Impact Investigation Exercise



Technical issues in solar PV integration with utility distribution grid





Power Quality Constraints

Response to Abnormal Voltages

RMS voltages at PCC	Maximum trip time
$V < 50\%$	6 cycles (0.12 sec)
$50\% < V < 88\%$	6 cycles (0.12 sec)
$88\% < V < 110\%$	Normal operation
$110\% < V < 137\%$	120 cycles (2.4 sec)
$137\% < V$	6 cycles (0.12 sec)

THD < 5% of fundamental frequency

Odd harmonics	Limit %	Even harmonics	Limit %
$3^{rd} - 9^{th}$	<4	$2^{nd} - 8^{th}$	<1
$11^{th} - 15^{th}$	<2	$12^{th} - 16^{th}$	<0.5
$17^{th} - 21^{st}$	<1.5	$18^{th} - 22^{nd}$	<0.375
$23^{rd} - 33^{rd}$	<0.6	$24^{th} - 34^{th}$	<0.15

Islanding Condition

Islanding detection time

10 cycles (0.2 sec) or less	50 % mismatch in P Load p.f. <0.95 (lead or lag)
2 seconds	Q.F. <2.5 Load p.f. >0.95 (lead or lag)


Islanding scenario in Indian conditions:

Quality Factor	1.6 to 2.5
Voltage Threshold	$80\% < V < 110\%$
Frequency Threshold	$47.5 \text{ Hz} < f < 50.5 \text{ Hz}$
Active Power Threshold	$-17.36\% < \frac{\Delta P}{P} < 56.25\%$
Reactive Power Threshold	$-27\% < \frac{\Delta Q}{P} < 4.925\%$
Total Harmonic Distortion	THD <4.92%

Risk Assessment of Unintentional Islanding Exercise


What is Unintentional Islanding ???

Process of elimination and identification of probable scenarios for unintended islanding




Most Probable Days and Time of Day (ToD) for formation of island

Winter - Nonworking days



Offpeak - Nonworking days






Goals for successful grid integration

Detection of islanding and disconnection of the PV system from the utility, regardless of the initial state of the system, perturbations, composition of the load

Detection of islanding which is sufficiently fast to guarantee safety and safeguard the reliability and integrity of the utility and PV systems

Disconnection of the PV system only when islanding is actually occurring (*no nuisance trips*)

Anti-Islanding Protection




$\Delta P > 0$
Under
voltage
relay



$\Delta P < 0$
Over
voltage
relay

$\Delta Q > 0$
Over
frequency
relay

$\Delta Q < 0$
Under
frequency
relay





Anti-Islanding Protection



Anti-Islanding Protection

Real time digital simulation




Unbalance Distribution Network Operations with PV Generation

Unbalance Distribution Networks under Study


IITGN-VGEC Network –
 An underground cable-fed actual spot network in India with 3 roof-top PV plants

21 Node Network, 400 V, small & spot network




Unbalance Distribution Network Operations with PV Generation (IITGN-VGEC)

Daily peak demand – with and without PV generation




maximum reduction in peak demand occurs in the months of February and March. However, the year-round net reduction in peak demand is found to be 68.75 kW.

Unbalance Distribution Network Operations with PV Generation (IITGN-VGEC)




average power factor consistently stays below 0.9 (lagging) during the months of February, March and partly April in the year 2012


- The drop in average power factor is shown expanded for a typical day (February 27, 2012).
- The real power demand sinks during sunshine hours due to real power injection from RPVs. Inverters of all RPVs are set to operate at unity power factor.



Renewable Energy Trading




Operational Framework for REC



Source: MNRE




Non-solar REC Trading



Non-Solar REC (Rs/REC)	Forbearance Price	Floor Price
	3300	1500



Solar REC Trading



Solar REC (Rs/REC)	Forbearance Price	Floor Price
	13,400	9300



Thank You !



Naran Pindoriya, IITGN